

ADDENDUM NO. 2**FOR****CITY OF BATAVIA, IL****NE & SE SUBSTATION UPDGRADES
CIRCUIT BREAKER PURCHASE****September 29, 2026**

ADD-2

1. The quantity of the 34.5kV Outdoor Dead Tank Vacuum Power Circuit Breaker has changed to eight (8).
The breakers should be marked per the following:
BKR 152-4, BKR 152-10, BKR 152-11, BKR 152-12, BKR 152-13, BKR 152-14, BKR 152-SP A, BKR 152-SP B.
2. The required continuous current ratings for the 34.5 kV Outdoor Dead Tank Vacuum Power Circuit Breakers shall be as follows: three (3) breakers rated at 2,000 amps and five (5) breakers rated at 1,200 amps.

END OF ADDENDUM

Please confirm receipt of this Addendum by signature and company. Please email to awooldridge@bhmg.com.

Name _____

Company _____